

CASE HISTORY

SEMICONDUCTOR
SOLAR
PHARMA
POWER GENERATION
FOOD & BEVERAGE
PULP AND PAPER
CHEMICAL
OIL AND GAS
MINING
AEROSPACE AND TRANSPORT
METAL FINISHING
MUNICIPAL



An **aquarion** Group Company

TOVEKO Filters

Indian Road - Muskoka



The District Municipality of Muskoka in Canada has a sewage works at Indian Road, which was upgraded to increase its flow handling capability and also improve discharge quality. The plant is designed to handle up to a peak flow of 550m³ per day (and subject to later expansion to 1000m³ per day) and has to produce a discharge quality of less than 0.3mg/l total phosphorous (as P) for discharge to Moon River.

As a part of the Contract, a model T-900 TOVEKO continuous gravity sand filter was supplied to provide tertiary filtration of treated wastewater prior to discharge to the river.

Part of the Consent required that the Owner submit a performance report immediately following the completion of the one-year performance testing period following commencement of operation of the Works.

The following summarised data is taken from a paper published by the Project's consultants, Totten Sims Hubicki Associates under their Project reference 52-7940-11. The theoretical design capacity of the plant during the test period was 275m³ per day.

| Daily Flow Data (m³ per day) | | | |
|--|----------------|----------------|----------------|
| | Maximum | Minimum | Average |
| August | 291 | 195 | 233 |
| September | 324 | 175 | 226 |
| October | 382 | 196 | 251 |
| November | 385 | 199 | 245 |
| December | 353 | 201 | 246 |
| January | 438 | 103 | 210 |
| February | 508 | 110 | 176 |
| March | 345 | 150 | 202 |
| April | 593 | 150 | 252 |
| May | 362 | 175 | 247 |
| June | 255 | 154 | 188 |
| July | 242 | 164 | 207 |
| Average | 373 | 164 | 224 |

| BOD5 Removal | | | |
|---------------------|--------------------------|------------------------------|-----------------------------|
| | Raw Sewage (mg/l) | Final Effluent (mg/l) | Removal Efficiency % |
| August | 93.25 | 2.00 | 97.86 |
| September | 73.25 | 2.00 | 97.27 |
| October | 58 | 2.00 | 96.55 |
| November | 53.25 | 2.00 | 96.24 |
| December | 46.33 | 2.00 | 95.68 |
| January | 44.33 | 2.00 | 95.49 |
| February | 50.33 | 3.00 | 94.04 |
| March | 1221 | 1.13 | 99.07 |
| April | 128.6 | 1.1 | 99.14 |
| May | 71.75 | 2.25 | 96.86 |
| June | 131.33 | 2.73 | 97.92 |
| July | 179.25 | 1.13 | 99.37 |
| Average | 87.58 | 1.96 | 97.76 |

| Suspended Solids Removal | | | |
|---------------------------------|------------------------------|----------------------------------|---------------------------------|
| | Raw Sewage (mg/l) | Final Effluent (mg/l) | Removal Efficiency % |
| August | 122.75 | 1.50 | 98.78 |
| September | 75.5 | 1.50 | 98.01 |
| October | 68.25 | 3.20 | 95.31 |
| November | 76.5 | 2.50 | 96.73 |
| December | 53.00 | 2.67 | 94.96 |
| January | 76.00 | 2.00 | 97.37 |
| February | 83.75 | 2.00 | 97.61 |
| March | 127.75 | 2.80 | 97.80 |
| April | 98.80 | 3.06 | 96.90 |
| May | 45.00 | 1.70 | 96.22 |
| June | 89.00 | 2.50 | 97.19 |
| July | 96.00 | 2.63 | 97.26 |
| Average | 84.38 | 2.34 | 97.23 |

| Total Phosphorous Removal | | | |
|----------------------------------|------------------------------|----------------------------------|---------------------------------|
| | Raw Sewage (mg/l) | Final Effluent (mg/l) | Removal Efficiency % |
| August | 3.12 | 0.06 | 98.08 |
| September | 3.14 | 0.03 | 99.04 |
| October | 2.12 | 0.04 | 98.11 |
| November | 2.01 | 0.05 | 97.51 |
| December | 1.21 | 0.16 | 86.78 |
| January | 2.33 | 0.05 | 97.85 |
| February | 1.88 | 0.11 | 94.15 |
| March | 4.26 | 0.09 | 97.89 |
| April | 2.48 | 0.11 | 95.56 |
| May | 2.37 | 0.11 | 95.36 |
| June | 3.68 | 0.14 | 96.20 |
| July | 2.13 | 0.10 | 95.31 |
| Average | 2.56 | 0.09 | 96.48 |

The overall data collected during the test period is summarised as follows:

| Parameter | Average results during test period | Consent Conditions |
|-------------------|---|-------------------------------|
| BOD ₅ | 1.96 | 10.0 |
| Suspended Solids | 2.34 | 10.0 |
| Total phosphorous | 0.09 | 0.3 |

The actual Consent conditions are:

| Parameter | Maximum Discharge Concentration (mg/l) |
|--------------------------------------|---|
| BOD ₅ | 10 |
| Suspended Solids | 10 |
| NH ₃ + NH ₃ -N | 0.5 (01 May – 31 Oct) 2.0 (01 Nov – 30 April) |
| Total phosphorous (as P) | <0.3 |
| Total residual chlorine | 0.09 |

H+E ranks among the world's leading suppliers in the fields of: water & wastewater treatment, and energy efficiency. Based on its global presence, the **H+E GROUP** has completed projects in over 50 countries.



HAGER+ELSÄSSER

An aquarion Group Company

Tel: +44 1403 272772

sales@he-water.co.uk
www.he-water.co.uk